



TC-14456


ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

CBIP Centre of Excellence, Ground Floor, Plot No. 21,

Sector 32, Gurugram-122001, Haryana, India.

Tel.: +91 (124) 2580021, E-mail:erdadel@erda.org Web: www.erda.org

**TEST REPORT** RP-2526-038430**ULR: TC1445626000004243F****SHEET : 1 of 6**

NAME AND ADDRESS OF CUSTOMER PVJ POWER SOLUTION PVT. LTD. VILLAGE NASRALI, P.O. DABHOTA TEHSIL NALAGARH, DISTT. SOLAN SOLAN-174101 HIMACHAL PRADESH, INDIA.		REPORT NO.: RP-2526-038430 DATE OF ISSUE: 12-02-2026	
		CUSTOMER REF.NO. PVJ/117/2026	DATE 03-02-2026
		DATE OF SAMPLE RECEIPT 10-02-2026	DATE OF TESTING 10-02-2026
		SAMPLE DESCRIPTION (As provided by customer) (Cast resin) Dry Type Transformer Manufactured by :PVJ Power Solution Pvt. Ltd., Nalagarh. Rating : 1600 KVA Volts : 33000/415 Volts (at no-load) Current : 27.99/2225.99 Amps. Phases : 3/3 % Impedance : 6.25 % ($\pm 10\%$) Frequency : 50 Hz Winding : Copper Vector group : Dyn11 Cooling : AN Guaranteed maximum total losses @ 50% : 7500 W Guaranteed maximum total losses @ 100% : 18000 W Guaranteed maximum temperature-rise of winding : 90°C	
TEST DETAILS As per sheet 2 of 6.		TEST SPECIFICATION As per sheet 2 of 6.	
TEST RESULTS : As per sheets from 3 of 6 to 5 of 6.			
ENCLOSURE : Photographs of test sample – As per sheet 6 of 6.			
Witnessed By: Pratyush Dabhar, Asst. Manager, PVJ Power Solution Pvt. Ltd., Nalagarh.			
REMARKS : 1) The transformer conforms to the guaranteed requirement as per above mentioned test specification for above mentioned test no. 1. 2) Criteria limit has not been specified for test no. 2.			
CHECKED BY 		APPROVED BY (Sandeep Kumar) 	
Note: 1. This report relates only to the particular sample received for testing in good condition at M/s. PVJ Power Solution Pvt. Ltd., Nalagarh. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. This report shall not be used for any purpose such as PR brochures, propaganda, advertisement and/or legal proceedings, unless for the granted purpose. 5. Only the tests asked for by the customer have been carried out. 6. Particulars of manufacturer/supplier, given in this report are based on information supplied by the customer, along with the test request/sample. ERDA does not assume any responsibility for the correctness of the information for above mentioned Sample Under Test (SUT). ERDA will not be responsible for any changes in SUT made after the test. This test report is given as per instrument status while testing. 7. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA within 10 years of date of issue of report.			

TC 0092331





TC-14456

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

CBIP Centre of Excellence, Ground Floor, Plot No. 21,

Sector 32, Gurugram-122001, Haryana, India.

Tel.: +91 (124) 2580021, E-mail:erdadel@erda.org Web: www.erda.org

**ULR: TC1445626000004243F****REPORT NO.:** RP-2526-038430**SHEET :** 6 of 6**DATE OF ISSUE:** 12-02-2026**PHOTOGRAPHS OF TEST SAMPLE**

DISTRIBUTION TRANSFORMER			
PVJ POWER			
DABHOTA INDUSTRIAL AREA			
HALLABATHI INDUSTRIAL AREA			
WWW.PVJPOWER.IN			
THREE PHASE OIL TYPE CAST RESIN TRANSFORMER			
STANDARD	IS 2026-11		
RATING	KVA 1600	MAX TOTAL LOSS AT 50% LOAD	W 7500
VOLT AT	H V 33000	MAX TOTAL LOSS AT 100% LOAD	W 18000
NO LOAD	L V 415	TYPE OF COOLING	AN
	H V 1170/AC-70KV	TEMP RISE	AMB°C 50
	L V -1 AC-3KV	VDG°C	90
CURRENT (AMP)	H V 27.99	CLASS OF INSULATION	F
	L V 2825.99	TOTAL MASS	KG 7000
FREQUENCY	Hz 50	MONTH/YEAR OF MFG	02/2026
VECTOR GROUP	D 5 II	SERIAL NUMBER	PVJ-0440
IMPEDANCE VOLT %	6.25/10%		
TAPPING	ELTC		
CTR HV VARIATION	L25 ±	STEPS	
TESTER			

W0-2526-016846/01

Dt - 10-02-2026

Bunni

TC-0092336

**CHECKED BY**

***** End of Test Report *****

DISTRIBUTION TRANSFORMER
PVJ POWER
PANDITA INDUSTRIAL AREA
BILASPUR DIST. JHARKHAND
751005 P.V. POWER LTD.
Mob: 991991658909

THREE PHASE DRY TYPE CAST RESIN TRANSFORMER

STANDARD	IS 2026-11
RATINGS	KVA 1000
VOLTAGE	HV 33KV
NO. LOAD	LV 415
WINDING	HV 1170AC/30KV
TEMP. RISE	50°C
CURRENT	HV 27.49
CLASS OF INSULATION	F
FREQUENCY	50
VECTOR GROUP	Dyn 11
IMPEDANCE VOLT %	0.25±10%
TAPPING	OLTC
FOR HV VARIATION	125% STEPS FROM +5% TO -16%

MADE IN INDIA

TAP POS.	OLTC CONC. EACH PH	HV VOLTS	LV VOLTS
1(MAX)	20-19	34650.0	415
2	20-18	34237.5	415
3	20-17	33825.0	415
4	20-16	33412.5	415
5(NOR)	20-15	33000.0	415
6	20-14	32587.5	415
7	20-13	32175.0	415
8	20-12	31762.5	415
9	20-11	31350.0	415
10	20-10	30937.5	415
11	20-09	30525.0	415
12	20-08	30112.5	415
13	20-07	29700.0	415
14	20-06	29287.5	415
15	20-05	28875.0	415
16	20-04	28462.5	415
17(MIN)	20-03	28050.0	415

DYN 11 VECTOR DIAGRAM

CONNECTION DIAGRAM

ERDA, GURUGRAM

Ref. No. RP-2026-078430

Date 12-2-26

Product Distribution Transformer


Verified by [Signature]

The drawing has been used for reference only.

REF/38-001

[Signature]
22/19/25

DESIGNED FOR PRODUCTION	HARSH	HARSH	MS	03.09.25
DESCRIPTION	DES	CHD	APPD	DATE
PVJ POWER SOLUTIONS PVT. LTD.		THE INFORMATION IS THE SOLE PROPERTY OF PVJ POWER SOLUTIONS PVT. LTD. and shall not be used, copied or reproduced in any form without its prior authorization.		
TRANSFORMER DIVISION		DRG NO. PD1/09/25 JOB NO. 43		
PANDITA INDUSTRIAL AREA		DRN	HARSH	03.09.25
BILASPUR DISTRICT, JHARKHAND		CHD	HARSH	03.09.25
TGA RATING PLATE		APPD	ADURGA	03.09.25
1000KVA 33.0KV 50/60HZ		SHEET NO. 01		
ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED		REV		



ERDA SIDE VIEW

Te. Report No. RD-2828-078436

Date 12-3-26

P. Product Substation Transformer

Verified by [Signature]

This drawing has been used for reference only.

REF / 38-001

S.L. NO.	DESCRIPTION	QTY
1	LOUVER OPENING	1
2	LV BUS DUCT	1
3	LV CABLE BOX	1
4	LV CABLE CHANNEL	1
5	LV CABLE	1
6	WEIGHTING LUG	1
7	ANTI SCANNER	1

NOTE:

1. ALL DIMENSION ARE IN MM.
2. THIS DRAWING DOES NOT PURPOSE TO SHOW THE EXACT CONSTRUCTION DETAIL OF THE TRANSFORMER. THERE MAY BE SOME DIFFERENCE IN EXECUTION BASE ON THE FINAL LAYOUTS. THE TRANSFORMER IS GUARANTEED FOR THE PERFORMANCE PARAMETER SPECIFIED IN THE ORDER.
3. OVERALL DIMENSION ARE SUBJECT TO $\pm 10\%$ TOLERANCE.
4. PAINT : RAL 7032

[Signature]
22/19/25