



Certificate No.: T-0071

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION
(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.
EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33
Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



TEST REPORT

SHEET 1 OF 28

NAME & ADDRESS OF CUSTOMER Bureau of Indian Standards, Parwanoo Branch office, House #15, Sector - 3, Parwanoo, District - Solan (HP) - 173220.	REPORT NO.: RP-1516-023647 DATE: 23.09.2015	
	CUSTOMER REF. NO:	DATED:
	PRBO/JK	19.08.2015
	DATE OF SAMPLE RECEIPT:	DATE OF TESTING:
	31.08.2015	11.09.2015 to 22.09.2015
SAMPLE DESCRIPTION 200 kVA Distribution Transformer (NON SEALED TYPE) 11000/433 Volts, 10.50/266.67 Amp., Oil filled, Vector Group: Dyn-11, ENERGY EFFICIENCY LEVEL: 2 Further details as per sheet No. 3 of 28.	SAMPLE IDENTIFICATION BIS SAMPLE CODE NO.: PRBO/JK/20150819/AS/01 SERIAL NO.: PVJ.200.01 YEAR OF MFG.: 2015 ERDA SAMPLE CODE NO.: ERDA-00104862	
	TEST DETAILS As per sheet 4 of 28.	
	TEST SPECIFICATIONS As per sheet 4 of 28.	
	ENCLOSURES: 1) As per sheet 2 of 28. 2) Photograph nos. ERDA-00104862/01 & 02	
SEAL DETAILS: Sample sealed with red wax seal		
REMARKS: On respective sheets from 5 of 28 to 28 of 28.		
PREPARED BY		APPROVED BY HITENDRA K. MISHRA

NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA.
2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.
4. Only test asked for by customer have been carried out.

5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.

TE 1532520

