



Certificate No. : TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

ULR-TC538919000033177F

Sheet : 1 of 11

NAME AND ADDRESS OF CUSTOMER M/s. PVJ POWER SOLUTION VILL. NASRALI, POST-DABHOTA, BHARATGARH ROAD, NALAGARH, HP-174101.	REPORT NO.: RP-1920-028374 DATE : 01.11.2019	
SAMPLE DESCRIPTION DISTRIBUTION TRANSFORMER (NON-SEALED TYPE) Manufactured by : PVJ POWER SOLUTIONS Rating : 630 kVA Volts : 11000/433 V (at no-load) Current : 33.1/840.0 Amps Phases : 3/3 Vector group : Dyn11 Energy efficiency level : 2 Further details as per sheet no.2	CUSTOMER REF. NO. PVJ/RKA/630-19a	DATE 11.10.2019
	DATE OF SAMPLE RECEIPT 11.10.2019	DATE OF TESTING 22.10.2019 to 31.10.2019
	SAMPLE IDENTIFICATION ERDA sample code number : ERDA-00339453 Manufacturer serial number : PVJ-630/01 Year of manufacture : 2019 Enclosed drawing numbers : 1) PVJ/630/11/L2/01 REV. 0 2) PVJ/630/11/L2/02 REV. 0	
TEST DETAILS As per sheet 3 of 11.	TEST SPECIFICATION As per sheet 3 of 11.	
TEST RESULTS : As per sheets from 4 of 11 to 10 of 11.		
ENCLOSURE : Photographs of test sample – As per sheet 11 of 11.		
REMARKS : 1) The transformer conforms to the guaranteed requirement as per above mentioned test specification for above mentioned test nos. 5 to 7 & 9 to 11. 2) Criteria limit has not been specified for test nos. 1 to 4 & 8.		
 PREPARED BY	 CHECKED BY	 APPROVED BY (Anil S. Khopkar)
Note : 1. This report relates only to the particular sample received for testing in good condition at ERDA, Makarpura. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director , ERDA. 4. Only the tests asked for by the customer have been carried out. 5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.		

TC 2881797

