



RAJASTHAN TEST & RESEARCH CENTRE

(IS/ISO/IEC 17025 - 2017)

Accredited to NABL

(A Constituent Board of Quality Council of India)

&

Recognized by BIS

(Ministry of Consumer Affairs, Food & Public Distribution, Govt. of India)



Test Report No.: **ULR-TC507323000000412F**

Name of Client : **PVJ POWER SOLUTIONS**

No. of Pages : **18 (Eighteen)**

NABL is Recognized by
INTERNATIONAL LABORATORY ACCREDITATION COOPERATION (ILAC)
ASIA PACIFIC ACCREDITATION COOPERATION (APAC)

This report is acceptable amongst all member countries of APAC & ILAC - Worldwide

Plot No.-296, Sector-7, IMT Manesar, Distt. Gurgaon-122050, (Haryana) INDIA

RAJASTHAN TEST & RESEARCH CENTRE

An ISO/IEC 17025:2017 Accredited Laboratory
Accredited to NABL vide Certificate No. TC-5073
Recognised by Bureau of Indian Standards (BIS)
DEWA (Dubai Electricity & Water Authority) Registration No. 103055
D-U-N-S Registration No. 737950000



An Electro-technical & Chemical Testing Laboratory

TEST REPORT

TEST REPORT NO: ULR-TC507323000000412F	Page No.: 1 of 18
--	-------------------

SECTION- A (GENERAL)

DATE OF RECEIPT OF TEST ITEM: 28/02/2023	DATE OF ISSUE OF TEST REPORT: 16/03/2023
1 JOB ID NUMBER	RTRC/JC/T/23B2801
2 NAME OF CUSTOMER	PVJ POWER SOLUTIONS
3 ADDRESS OF CUSTOMER	VILL. NASRALI, PO DABHOTA, NALAGARH, NALAGARH, SOLAN, HIMACHAL PRADESH, INDIA-174101
4 CUSTOMER REFERENCE No. AND DATE	Test request date 28.02.2023
5 ITEM DESCRIPTION	3 PHASE, 800 KVA, 11/0.433 KV CRGO CORE, COPPER WOUND NON SEALED TYPE OCTC TRANSFORMER
6 MODE OF PACKING	NIL
7 CONDITION (WHEN RECEIVED)	Satisfactory
8 QUANTITY OF ITEM	1 No.
9 SEAL NUMBER (IF ANY)	NIL
10 TESTS TO BE CONDUCTED	Type Test (As per page no. 4)
11 REFERENCE SPECIFICATION	IS 1180 (Part-1): 2014 (upto & amendment no. 4)
12 DISCIPLINE	Electrical Testing
13 GROUP	Inductors and Transformers
14 DATE OF STARTING TESTS	14/03/2023
15 DATE OF COMPLETION OF TESTS	16/03/2023
16 ADDITIONS, DEVIATIONS OR EXCLUSIONS (IF ANY)	NIL



Authorized Signatory

[Signature]

F/TR/37(1180-01/07/Amd. 04) Rev. No. 05



17	NAME OF THE FIRM	NIL
18	IDENTIFICATION	Date of Manufacturing: 12/2022, Shelf Life/Expiry/Best Before: ..., Batch Number/Control Unit Number: 800/EEL2/01, Quantity: 1, Mode of Disposal: To be returned to manufacturer, Grade/Type/Variety/ Size/ Class/ Rating: 3 PHASE, 800 KVA, 11/0.433 KV CRGO CORE, COPPER WOUND NON SEALED TYPE OCTC TRANSFORMER, Serial Number: 800/EEL2/01, Test required: All, Total Parts: 1, Sample Code: 804207/2023/SS/3, QR Code Number: 100000034532
19	TEST WITNESSED BY (CUSTOMER REPRESENTATIVE)	NIL
20	TEST WITNESSED BY (OTHER THAN CUSTOMER)	NIL
21	TEST SUBCONTRACTED WITH ADDRESS OF THE LABORATORY	NIL
22	SPECIFIC TEST CONDITIONS (IF ANY)	N/A
23	RATING NAME PLATE	Photograph attached at page no. 18
24	YEAR OF MFG	2022
25	ENCLOSURE	1. NAME PLATE DRAWING No.: PVJ-800L2-RD-02-REV.0 2. OGA DRAWING No.: PVJ-800L2-GA-01-REV.0
26	WHETHER THE RESULTS CONFORM TO SPECIFICATIONS/ISS OR NOT	The Sample conforms the requirements for the tests carried out as per IS 1180 (Part-1): 2014 (upto & amendment no. 4)
Note:- Hologram is fixed on each page of the test report.		



Authorized Signatory

